

# FISH CREEK ISD (aka Wilson Meadows) 2015 WATER QUALITY REPORT

### Is my water safe?

YES!! Your water complies with the standards set by the Safe Drinking Water Act (SDWA). We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the SDWA. This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

# Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

#### Where does my water come from?

Wilson Meadows Water System is supplied by four groundwater wells.

#### How can I get involved?

Contact Jorgensen Associates with questions regarding your water system and how to get involved.

### Variances, Exemptions, and Violations

The water system does not operate under any variances or exemptions and has no violations.

### Description of the water treatment process

Thanks to the high quality of the groundwater source, your water is delivered to you untreated.

In the case of emergency, or during maintenance, your water system is equipped with a chlorine disinfection system. Disinfection involves the addition of chlorine to kill bacteria and other microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

# FISH CREEK ISD (aka Wilson Meadows) PWS WY5601473

#### Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

- microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;
- inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming;
- pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;
- organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems;
- and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### **Additional Information on Lead**

NO lead was detected in the water supply. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The water supplier is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <a href="http://www.epa.gov/safewater/lead">http://www.epa.gov/safewater/lead</a>.

The water supply system was constructed in the late 1990s, after 1986 when lead was prohibited in potable water system appurtenances, and was constructed using materials that were lead free. The water mains are PVC and the service lines are polyethylene (PE) to the property line, both are approved

for potable water. The definition of lead free does allow for trace amounts of lead in potable water appurtenances, and flushing your tap before using water for drinking or cooking is recommended.

## **Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Additionally, the EPA requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. Although many more contaminants were tested, only those substances listed below were found in your water. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

									1	
	MCLG	MCL,								
	or	TT, or		Ra	nge	Sample				
<u>Contaminants</u>	MRDLG	MRDL	Water	<u>Low</u>	High	<u>Date</u>	Vio	lation		Typical Source
Inorganic Contaminants										
Fluoride (ppm)	4	4	0.2	NA		2013		No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer	
Nitrate [measured as Nitrogen] (ppm)	10	10	0.2	NA	NA	2015		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	
Microbiological Contaminants										
Total Coliform (positive samples/month)	0	1	0	NA		2015		No	- 1	laturally present in the nvironment
	•		•		•	•				
Radioactive Contami	nants									
Radium (combined 226/228) (pCi/L)	0	5 0.8		NA		2013	No		Ere	osion of natural deposits
Gross Alpha Excluding Radon &	0	15	3.1	3.3	3.3	2013		No		osion of natural deposits
	ı									
			Your	Sam		•	# Samples		ds	
<u>Contaminants</u>	MCLG	<u>AL</u>	Water	Dat	<u>e</u>	Exceedin	g AL	<u>AL</u>		<u>Typical Source</u>
Inorganic Contamina	<del></del>									
Copper - action level at consumer taps (ppm)	1.3	1.3	0.86	2014		1		No		Corrosion of household plumbing systems; Erosion of natural
Lead - action level at consumer taps (ppb)	0	15	0	2014		0	0			Corrosion of household plumbing systems;  Frosion of natural

Unit Descriptions								
Term		Definition						
ppm		ppm: parts per million, or milligrams per liter (mg/L)						
ppb		ppb: parts per billion, or micrograms per liter (μg/L)						
pCi/L		pCi/L: picocuries per liter (a measure of radioactivity)						
positive samples/month		positive samples/month: Number of samples taken monthly that were found to be positive						
NA		NA: not applicable						
ND		ND: Not detected						
NR		NR: Monitoring not required, but recommended.						
Important Drinking Water Definitions								
Term	Definition							
MCLG		taminant Level Goal: The level of a contaminant in drinking water no known or expected risk to health. MCLGs allow for a margin of						
MCL		minant Level: The highest level of a contaminant that is allowed in are set as close to the MCLGs as feasible using the best available						
TT	TT: Treatment Technique: A required process intended to reduce the leve contaminant in drinking water.							
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.							
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.							
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.							
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.							
MNR		MNR: Monitored Not Regulated						
MPL	М	PL: State Assigned Maximum Permissible Level						

Jorgensen Associates Attn: Brian Lenz

PO Box 9550 / 1315 S. HWY 89 Suite 201

For more information please contact:

Jackson, WY 83002 Phone: 307 733-5150 Fax: 307 733-5187

E-Mail: blenz@jorgensenassociates.com Website: <a href="https://www.jorgensenassociates.com">www.jorgensenassociates.com</a>